

Sec. 18-229. Public water, fire hydrants, and sewer systems.

- A Subdivisions that incorporate a public water distributions system and/or a public sewage collection system shall require that all future homeowners connect to the public water and/or sewer system prior to the issuance of a certificate of occupancy for their principal structure. All subdivisions incorporating a public water distribution system and/or a public sewage collection system, shall comply with the standards of the applicable state, county and local agencies.
- B Fire hydrants shall be provided in accordance with National Fire Protection Association standards. Adequate flow for firefighting will be available to every lot in the subdivision. This provision will require that the main lines be a minimum six inches in diameter, and that a hydrant tee and valve be provided within 500 feet of each lot, unless otherwise approved by the Johnston County Fire Marshal.

DRAFT